

# SHUT OFF KITS

## SHUT OFF KIT (SOK) FOR TASKMASTER III™ VALVES

The Task Master III™ is designed to allow untreated water to bypass a softener or filter if the unit is in regeneration. Shut off kits may be installed at the softener outlets to prevent bypass of untreated water. The shut off kit is wired into the valve control circuit to operate when a softener is in regeneration. During regeneration, the solenoid on the shut off kit is energized and by-pass is eliminated.

Shut off kits are required on twin alternating units. When one unit is in service the other must be in standby or regeneration. The shut off kit isolates the standby unit until it goes into service. For twin alternating units, hard water normally available at the valve outlet during regeneration will then be shut off and soft water will continuously be provided to service from the opposite unit.

SHUT OFF KIT PART NUMBERS	
SIZE	No.
¾"	720081
1"	720082
1½"	720088
2"	720089
2½"	720090
3"	720003
4"	720004

CAT370.2

