



EDR AND FLOW METER

NOTE:  
 FLOW METER REQUIRES (15) PIPE DIAMETER LENGTHS BEFORE METER & (10) AFTER FOR PROPER OPERATION

PIPING SHOWN IN DASHED LINES IS TO BE SUPPLIED BY CUSTOMER ACTUAL LOCATION & LENGTH MAY VARY

REV. No.	REVISION	DATE	CR/TA
0	PRELIMINARY		
1			

  

<b>Water King</b> <small>Water Conditioning</small>	
102 Clarkmont Rd., Buena, Louisiana, U.S.A. 70039 Telephone: (504) 688-2890 Fax: (504) 681-7922 <a href="http://www.waterking.com">www.waterking.com</a>	

  

RE-240-T TWIN AIR WATER SOFTENER TYPICAL PIPING ARRANGEMENT	DATE: 10/4/08 DRAWING NUMBER: WKR240T SHEET: 1 / 1
--	--