



PIPING SHOWN IN DASHED LINES IS TO BE SUPPLIED BY CUSTOMER. ACTUAL LOCATION & LENGTH MAY VARY.

NOTE:
FLOW METER REQUIRES (6) PIPE DIAMETER LENGTHS BEFORE METER & (10) AFTER FOR PROPER OPERATION

REV.	NO.	REVISION	DATE	BY	CHKD.
0		PRELIMINARY			
1					

Water King
FAKOR CORPORATION
 Water King, Inc.
 102 Charbonnet Rd., Baton Rouge, Louisiana, U.S.A. 70809
 Telephone: (504) 988-2900 • Fax: (504) 981-7922
www.waterking.com

NO.	DATE	BY	CHKD.	REV.
1	05/10/2007			
2	05/10/2007			
3	05/10/2007			
4	05/10/2007			
5	05/10/2007			
6	05/10/2007			
7	05/10/2007			
8	05/10/2007			
9	05/10/2007			
10	05/10/2007			

WATER KING
 MF-1200-S-25-TA SOFTENER
 TYPICAL PIPING ARRANGEMENT

DATE: 05/10/2007
 DRAWN BY: WKM/PT200S25-TA
 CHECKED BY: WKM/PT200S25-TA
 SHEET NO. 1 / 1