



PIPING SHOWN IN DASHED LINES IS TO BE SUPPLIED BY CUSTOMER. ACTUAL LOCATION & LENGTH MAY VARY

NOTE:
 FLOW METER REQUIRES (15) PIPE DIAMETER LENGTHS BEFORE METER & (10) AFTER FOR PROPER OPERATION
 FLOW METER SHOULD BE MOUNTED HORIZONTALLY

| BY: No. | REVISION | DATE | CD |
|--|-------------------|------------|----|
| 1 | PRELIMINARY | 10/24/2007 | |
| 1 | UPDATE BRINE TANK | 03/24/2009 | |
| | | | |
| | | | |
| | | | |
| 102 Charbonnet Rd., Duson, Louisiana, U.S.A. 70529 | | | |

| | | |
|-------------------|--------|---|
| | | 923452-11 MF-450-S3-TA/TS SOFTENER TYPICAL PIPING ARRANGEMENT SHEET |
| SCALE @ 2 1/2"=1' | N.T.S. | DRAWING NUMBER WKMF450-S3-TA 01 / 0 1 www.waterking.com |