



PIPING SHOWN IN DASHED LINES IS TO BE SUPPLIED BY CUSTOMER

NOTE:
 FLOW METER REQUIRES (15) PIPE DIAMETER LENGTHS BEFORE METER & (10) AFTER FOR PROPER OPERATION

BY/ NO.	REVISION	DATE	DESCRIPTION
0	PRELIMINARY	01/17/92	
1	UPDATE CONTROL VALVE	12/15/08	
2	UPDATE BRINE TANK	03/17/2009	

920240-11	
MF-240 TWIN ALTERNATING SOFTENER	
TYPICAL PIPING ARRANGEMENT	
SCALE @ 24"x36"	SHEET
N.T.S.	01 / 01
DRAWING NUMBER	WKMF240T
www.waterking.com	

102 Charbonnet Rd., Duson, Louisiana, U.S.A. 70529	
Telephone: (337) 988-2360 * Fax: (337) 981-7922	