



PIPING SHOWN IN DASHED LINES IS TO BE SUPPLIED BY CUSTOMER
 ACTUAL LOCATION & LENGTH MAY VARY

NOTE:
 FLOW METER REQUIRES (15) PIPE DIAMETER LENGTHS BEFORE METER & (10) AFTER FOR PROPER OPERATION

BY: No.	REVISION	DATE	CKD
0	PRELIMINARY	8/17/99	
1	UP-DATE CONTROL VALVE	12/15/08	
2	UP-DATE BRINE TANK	03/17/2009	

920240-11	
MF-240 TWIN ALTERNATING SOFTENER TYPICAL PIPING ARRANGEMENT	
SCALE @ 24"x36"	DRAWING NUMBER
N.T.S.	WKMF240T
	SHEET
	01 / 0 1
www.waterking.com	

Telephone: (337) 988-2360 * Fax: (337) 981-7922	