



NOTE:
 PIPING SHOWN IN DASHED LINES IS
 TO BE SUPPLIED BY CUSTOMER
 ACTUAL LOCATION & LENGTH MAY VARY

NOTE:
 FLOW METER REQUIRES (15) PIPE DIAMETER
 LENGTHS BEFORE METER & (10) AFTER FOR
 PROPER OPERATION

BY: NO.	REVISION	DATE	CD
0	PRELIMINARY	9/24/09	
1	UPDATE CONTROL VALVE	10/25/09	

920602-11	
MF-600 TWIN ALTERNATING SOFTENER	
TYPICAL PIPING ARRANGEMENT	
SCALE @ 24"X36"	SHEET
N.T.S.	01 / 0 1
DRAWING NUMBER WKMF600T	
www.waterking.com	

102 Charbonnet Rd., Duson, Louisiana, U.S.A. 70529	Telephone: (337) 988-2360 * Fax: (337) 981-7922
--	---