



PIPING SHOWN IN DASHED LINES IS TO BE SUPPLIED BY CUSTOMER
ACTUAL LOCATION & LENGTH MAY VARY

NOTE:
FLOW METER REQUIRES (15) PIPE DIAMETER LENGTHS BEFORE METER & (10) AFTER FOR PROPER OPERATION

BY: No.	REVISION	DATE	CC'D
0	RELEASED	08/23/99	
1	UP-DATE BRINE TANK	10/29/06	
3	UPDATE CONTROL VALVE	10/23/2007	

102 Charbonnet Rd., Duson, Louisiana, U.S.A. 70529
Telephone: (337) 988-2360 * Fax: (337) 981-7922

WATER CONDITIONING

920752-11	MF-750 TWIN ALTERNATING SOFTENER
SCALE @ 3/4"=36"	TYPICAL PIPING ARRANGEMENT
N.T.S.	DRAWING NUMBER
01 / 0 1	WKMF750T
WWW.WATERKING.COM	SHEET