


TOP VIEW



ELEVATION

NOTES:

- 1) PIPING SHOWN IN DASHED LINES TO BE SUPPLIED BY CUSTOMER.
- 2) ALLOW 1 FOOT ABOVE TANKS FOR LOADING.
- 3) FLOW METER REQUIRES (15) PIPE DIAMETER LENGTHS BEFORE METER & (10) AFTER FOR PROPER OPERATION.
- 4) FLOW METER SHOULD BE MOUNTED HORIZONTALLY.

| | |
|------------------|-----------|
| SHIPPING WEIGHT | 1880 Lbs. |
| OPERATING WEIGHT | |

| BY: No. | REVISION | DATE | CK'D |
|---------|------------------------|------------|------|
| RLR 0 | SUBMITTAL FOR APPROVAL | 05/27/2014 | JEB |
| | | | |
| | | | |
| | | | |
| | | | |

Water King

921182-11
MF-180S-2-TA WATER SOFTENER
GENERAL ARRANGEMENT

| | | |
|--------|----------------|---------|
| SCALE | DRAWING NUMBER | SHEET |
| N.T.S. | MF-180S-2"-TA | 01 / 01 |

102 Charbonnet Rd., Duson, Louisiana, 70529, U.S.A.

Telephone: (337) 988-2360 * Fax: (337) 981-7922

www.waterking.com