



PIPING SHOWN IN DASHED LINES IS TO BE SUPPLIED BY CUSTOMER. ACTUAL LOCATION & LENGTH MAY VARY

NOTE:
 FLOW METER REQUIRES (15) PIPE DIAMETER LENGTHS BEFORE METER & (10) AFTER FOR PROPER OPERATION
 FLOW METER SHOULD BE MOUNTED HORIZONTALLY

BY: No.	REVISION	DATE	CD
1	PRELIMINARY	10/24/2007	
1	UPDATE BRINE TANK	03/24/2009	

102 Charbonnet Rd., Duson, Louisiana, U.S.A. 70529
 Telephone: (337) 988-2360 * Fax: (337) 981-7922



923452-11	
MF-450-S3-TA/TS SOFTENER	
TYPICAL PIPING ARRANGEMENT	
SCALE @ 2 1/2"=1'	DRAWING NUMBER
N.T.S.	WKMF450-S3-TA
	01 / 0 1
www.waterking.com	