



PIPING SHOWN IN DASHED LINES IS TO BE SUPPLIED BY CUSTOMER
ACTUAL LOCATION & LENGTH MAY VARY

NOTE:

FLOW METER REQUIRES (15) PIPE DIAMETER LENGTHS BEFORE METER & (10) AFTER FOR PROPER OPERATION

BY: No.	REVISION	DATE	CKD
0	PRELIMINARY	8/17/99	
1	UP-DATE CONTROL VALVE	12/15/08	
2	UP-DATE BRINE TANK	03/17/2009	

Water King
WATER CONDITIONING

920240-11
MF-240 TWIN ALTERNATING SOFTENER
TYPICAL PIPING ARRANGEMENT

Telephone: (337) 988-2360 * Fax: (337) 981-7922

SCALE @ 24"X36"	DRAWING NUMBER	SHEET
N.T.S.	WKMF240T	01 / 0 1

www.waterking.com