



NOTE:
 PIPING SHOWN IN DASHED LINES IS
 TO BE SUPPLIED BY CUSTOMER
 ACTUAL LOCATION & LENGTH MAY VARY

NOTE:
 FLOW METER REQUIRES (15) PIPE DIAMETER
 LENGTHS BEFORE METER & (10) AFTER FOR
 PROPER OPERATION

BY: No.	REVISION	DATE	NO.
0	PRELIMINARY	8/23/99	000
1	UPDATE CONTROL VALVE	12/15/08	
2	UPDATE BRINE TANK	03/24/2009	

		920302-11 MF-300 TWIN ALTERNATING SOFTENER TYPICAL PIPING ARRANGEMENT
SCALE @ 4" X 36"	DRAWING NUMBER	SHEET
N.T.S.	WKMF300T	01 / 0 1

Telephone: (337) 988-2360 * Fax: (337) 981-7922
 102 Charbonnet Rd., Dubon, Louisiana, U.S.A. 70529
 www.waterking.com