



NOTE:
 PIPING SHOWN IN DASHED LINES IS
 TO BE SUPPLIED BY CUSTOMER
 ACTUAL LOCATION & LENGTH MAY VARY

NOTE:
 FLOW METER REQUIRES (15) PIPE DIAMETER
 LENGTHS BEFORE METER & (10) AFTER FOR
 PROPER OPERATION

BY: No.	REVISION	DATE	DESCRIPTION
0	PRELIMINARY	8/23/09	
1	UPDATE CONTROL VALVE	12/15/08	
2	UPDATE BRINE TANK	03/24/2009	

920452-11		MF-450 TWIN ALTERNATING SOFTENER	
TYPICAL PIPING ARRANGEMENT		SCALE @ 1/4" = 3'	
N.T.S.	DRAWING NUMBER	WKMFA50T	SHEET
			01 / 01

102 Charbonnet Rd., Dubon, Louisiana, U.S.A. 70529
 Telephone: (337) 988-2360 * Fax: (337) 981-7922
 www.waterking.com