



**NOTE:**  
 PIPING SHOWN IN DASHED LINES IS TO BE SUPPLIED BY CUSTOMER  
 ACTUAL LOCATION & LENGTH MAY VARY

**NOTE:**  
 FLOW METER REQUIRES (15) PIPE DIAMETER LENGTHS BEFORE METER & (10) AFTER FOR PROPER OPERATION

BY: NO.	REVISION	DATE	CD
0	PRELIMINARY	9/24/09	
1	UPDATE CONTROL VALVE	10/25/09	

102 Charbonnet Rd., Duson, Louisiana, U.S.A. 70529

Telephone: (337) 988-2360 \* Fax: (337) 981-7922

**Water King**  
 WATER CONDITIONING

920602-11  
 MF-600 TWIN ALTERNATING SOFTENER  
 TYPICAL PIPING ARRANGEMENT

SCALE @ 24"X36"

N.T.S.

DRAWING NUMBER  
 WKMF600T

SHEET  
 01 / 0 1

www.waterking.com