



FRONT VIEW

- NOTES:
- 1) PIPING SHOWN IN DASHED LINES - SUPPLIED BY CUSTOMER
 - 2) ALLOW 1 FOOT ABOVE TANKS FOR LOADING
 - 3) FLOW METER REQUIRES (15) PIPE DIAMETER LENGTHS BEFORE METER & (10) AFTER FOR PROPER OPERATION
 - 4) FLOW METER SHOULD BE MOUNTED HORIZONTALLY

REV.	DATE	DESCRIPTION
0	01/06/2009	PRELIMINARY
1	03/15/2011	ADD SECOND BRINE TANK, TOP VIEW

910153-10	RF-150-Tri. TRIPLEX WATER SOFTENER
TYPICAL PIPING ARRANGEMENT	
SCALE @ 24"x36"	DRAWING NUMBER
N.T.S.	WKRKF150TRI
	01 / 0 1

Telephone: (337) 988-2360 * Fax: (337) 981-7922
 102 Charbonnet Rd., Duson, Louisiana, U.S.A. 70529
 www.waterking.com

