



FRONT VIEW

- NOTES:
- 1) PIPING SHOWN IN DASHED LINES - SUPPLIED BY CUSTOMER
 - 2) ALLOW 1 FOOT ABOVE TANKS FOR LOADING
 - 3) FLOW METER REQUIRES (15) PIPE DIAMETER LENGTHS BEFORE METER & (10) AFTER FOR PROPER OPERATION
 - 4) FLOW METER SHOULD BE MOUNTED HORIZONTALLY

REV.	DATE	DESCRIPTION
0	01/06/2009	PRELIMINARY
1	03/15/2011	ADD SECOND BRINE TANK, TOP VIEW



910153-10
 RF-150-Tri. TRIPLEX WATER SOFTENER
 TYPICAL PIPING ARRANGEMENT
 SCALE @ 24"x36"
 N.T.S.
 DRAWING NUMBER: WKKRF150TRI
 SHEET: 01 / 0 1
 www.waterking.com

Telephone: (337) 988-2360 * Fax: (337) 981-7922
 102 Charbonnet Rd., Duson, Louisiana, U.S.A. 70529