



NOTE:
 FLOW METER REQUIRES (15) PIPE DIAMETER LENGTHS BEFORE METER & (10) AFTER FOR PROPER OPERATION

PIPING SHOWN IN DASHED LINES IS TO BE SUPPLIED BY CUSTOMER
 ACTUAL LOCATION & LENGTH MAY VARY

REV. NO.	REVISION	DATE	BY
0	PRELIMINARY	10/04/09	
1	UPDATE CONTROL VALVE	9/22/2007	
2	UPDATE BRINE VALVE	03/17/2009	

Water King
 WATER CONDITIONING

910242-11
 RF-240 TWIN ALTERNATING
 TYPICAL PIPING ARRANGEMENT

SCALE @ 24"=36"
 N.T.S.

DRAWING NUMBER: WKRF240T
 SHEET: 01 / 0 1
 www.waterking.com

102 Charbonnet Rd., Duson, Louisiana, U.S.A. 70529
 Telephone: (337) 988-2360 * Fax: (337) 981-7922