



**NOTE:**  
 FLOW METER REQUIRES (15) PIPE DIAMETER LENGTHS BEFORE METER & (10) AFTER FOR PROPER OPERATION

PIPING SHOWN IN DASHED LINES IS TO BE SUPPLIED BY CUSTOMER  
 ACTUAL LOCATION & LENGTH MAY VARY

REV. NO.	REVISION	DATE	BY
0	PRELIMINARY	10/04/09	
1	UPDATE CONTROL VALVE	9/22/2007	
2	UPDATE BRINE VALVE	03/17/2009	

**Water King**  
WATER CONDITIONING

910242-11  
 RF-240 TWIN ALTERNATING  
 TYPICAL PIPING ARRANGEMENT

SCALE: 0.24"=1'-0"	DRAWING NUMBER: WKRF240T
N.T.S.	SHEET: 01 / 0 1

Telephone: (337) 988-2360 \* Fax: (337) 981-7922  
 102 Charbonnet Rd., Duson, Louisiana, U.S.A. 70529  
[www.waterking.com](http://www.waterking.com)