



TOP VIEW

BY-PASS (NC)

INLET

OUTLET

FLOW METER

ELECTRONIC REGENERATION CONTROLLER ERCD

TASK MASTER III VALVE

TO DRAIN 3/4"

85"

MINERAL TANK 24"x72"

BRINE TANK 24"x50"

MINERAL TANK 24"x72"

Min.84"

FRONT VIEW

- NOTES:
- 1) PIPING SHOWN IN DASHED LINES - SUPPLIED BY CUSTOMER
 - 2) ALLOW 1 FOOT ABOVE TANKS FOR LOADING
 - 3) FLOW METER REQUIRES (15) PIPE DIAMETER LENGTHS BEFORE METER & (10) AFTER FOR PROPER OPERATION
 - 4) FLOW METER SHOULD BE MOUNTED HORIZONTALLY

J:\Drawings\catalog\RF\WKRF240T.dwg, 3/15/2011 11:04:40 AM, RaymondRichardson, Adobe PDF, Letter, 1:19.5009, Water King Inc.

SHIPPING Wt.	1390 lbs.
OPERATING Wt.	

BY:	No.	REVISION	DATE	CK'D
.	0	PRELIMINARY	10/04/99	.
	1	UP-DATE CONTROL VALVE	9/25/2007	
	2	UP-DATE , ADD TOP VIEW	03/15/2011	



910242-11		
RF-240 TWIN ALTERNATING		
TYPICAL PIPING ARRANGEMENT		
SCALE @ 24"x36"	DRAWING NUMBER	SHEET
N.T.S.	WKRF240T	01 / 0 1
www.waterking.com		

102 Charbonnet Rd., Duson, Louisiana, U.S.A. 70529

Telephone: (337) 988-2360 * Fax: (337) 981-7922