



- NOTES:
- 1) PIPING SHOWN IN DASHED LINES - SUPPLIED BY CUSTOMER
 - 2) ALLOW 1 FOOT ABOVE TANKS FOR LOADING
 - 3) FLOW METER REQUIRES (15) PIPE DIAMETER. LENGTHS BEFORE METER & (10) AFTER FOR PROPER OPERATION
 - 4) FLOW METER SHOULD BE MOUNTED HORIZONTALLY

BY:	NO.	REVISION	DATE	REV
	0	PRELIMINARY	12/17/2009	
	1			
	2			

Water King
WATER CONDITIONING

Telephone: (337) 988-2360 • Fax: (337) 981-7922
102 Charbonnet Rd., Duson, Louisiana, U.S.A. 70529