



TOP VIEW

INLET

BY-PASS (NC)

OUTLET

FLOW METER

FLOW METER

ELECTRONIC REGENERATION CONTROLLER ERcD

TASK MASTER III VALVE

TO DRAIN 1-1/2"

MINERAL TANK 30"x72"

BRINE TANK 24"x50"

MINERAL TANK 30"x72"

89"

Min. 9'-0"

FRONT VIEW

NOTES:

- 1) PIPING SHOWN IN DASHED LINES - SUPPLIED BY CUSTOMER
- 2) ALLOW 1 FOOT ABOVE TANKS FOR LOADING
- 3) FLOW METER REQUIRES (15) PIPE DIAMETER LENGTHS BEFORE METER & (10) AFTER FOR PROPER OPERATION
- 4) FLOW METER SHOULD BE MOUNTED HORIZONTALLY

J:\Drawings\catalog\RF\WKRF300T.p.dwg, 3/15/2011 12:02:32 PM, RaymondRichardson, Adobe PDF, Letter, 1:21.4509, Water King Inc.

SHIPPING WT. 2525 lbs.
OPERATING WT. 1500 lbs.

BY:	No.	REVISION	DATE	CK'D
.	0	PRELIMINARY	07/13/06	.
.	1	UP-DATE BRINE TANK	03/17/2009	.
.
.
.
102 Charbonnet Rd., Duson, Louisiana, U.S.A. 70529				



Telephone: (337) 988-2360 * Fax: (337) 981-7922

910302		
RF-300 TWIN PARALLEL SOFTENER TYPICAL PIPING ARRANGEMENT		
SCALE @ 24"x36"	DRAWING NUMBER	SHEET
N.T.S.	WKRF300T	01 / 0 1
www.waterking.com		