



NOTES:

- 1) PIPING SHOWN IN DASHED LINES - SUPPLIED BY CUSTOMER
- 2) ALLOW 1 FOOT ABOVE TANKS FOR LOADING
- 3) FLOW METER REQUIRES (15) PIPE DIAMETER LENGTHS BEFORE METER & (10) AFTER FOR PROPER OPERATION
- 4) FLOW METER SHOULD BE MOUNTED HORIZONTALLY

SHIPPING Wt.	440 Lbs.
OPERATING Wt.	.

BY:	No.	REVISION	DATE	CKD
	0	PRELIMINARY	10/15/04	
	1	UPDATE VALVE	9/21/2007	
	2	ADD TOP VIEW	03/10/2011	

102 Charbonnet Rd., Duson, Louisiana, U.S.A. 70529

Water King
WATER CONDITIONING

910052-11 RF-50-TA WATER SOFTENER TYPICAL PIPING ARRANGEMENT		
SCALE @ 24"x36"	DRAWING NUMBER	SHEET
N.T.S.	WKR50T	01 / 0 1
www.waterking.com		