



NOTES:

- 1) PIPING SHOWN IN DASHED LINES - SUPPLIED BY CUSTOMER
- 2) ALLOW 1 FOOT ABOVE TANKS FOR LOADING
- 3) FLOW METER REQUIRES (15) PIPE DIAMETER LENGTHS BEFORE METER & (10) AFTER FOR PROPER OPERATION
- 4) FLOW METER SHOULD BE MOUNTED HORIZONTALLY

| | |
|---------------|----------|
| SHIPPING Wt. | 440 Lbs. |
| OPERATING Wt. | . |

| BY: | No. | REVISION | DATE | CKD |
|-----|-----|--------------|------------|-----|
| | 0 | PRELIMINARY | 10/15/04 | |
| | 1 | UPDATE VALVE | 9/21/2007 | |
| | 2 | ADD TOP VIEW | 03/10/2011 | |
| | | | | |
| | | | | |

102 Charbonnet Rd., Duson, Louisiana, U.S.A. 70529



| | | |
|--|----------------|----------|
| 910052-11 RF-50-TA WATER SOFTENER TYPICAL PIPING ARRANGEMENT | | |
| SCALE @ 24"x36" | DRAWING NUMBER | SHEET |
| N.T.S. | WKR50T | 01 / 0 1 |
| www.waterking.com | | |