



TOP VIEW

INLET

BY-PASS (NC)

OUTLET

FLOW METER

ELECTRONIC REGENERATION CONTROLLER ERCd

TASK MASTER III VALVE

TO DRAIN

65"

MINERAL TANK
13"x54"

BRINE TANK
18"x40"

MINERAL TANK
13"x54"

Min 62"

FRONT VIEW

NOTES:

- 1) PIPING SHOWN IN DASHED LINES - SUPPLIED BY CUSTOMER
- 2) ALLOW 1 FOOT ABOVE TANKS FOR LOADING
- 3) FLOW METER REQUIRES (15) PIPE DIAMETER LENGTHS BEFORE METER & (10) AFTER FOR PROPER OPERATION
- 4) FLOW METER SHOULD BE MOUNTED HORIZONTALLY

SHIPPING WT.	565 LBS.
OPERATING WT.	.

BY:	No.	REVISION	DATE	CK'D
.	0	PRELIMINARY	9/30/99	.
.	1	UPDATE BRINE TANK AND CONTROL VALVE	09/24/2007	.
.	2	UPDATE, ADD TOP VIEW	03/11/2011	.
.				.



910072-11 RF-70-TA WATER SOFTENER TYPICAL PIPING ARRANGEMENT		
SCALE @ 24"x36"	DRAWING NUMBER	SHEET
N.T.S.	WKRF70T	01 / 0 1
www.waterking.com		